

The Foster® products, shown in the table below, comply with U.S. Green Building Council's LEED® requirements for Indoor Environmental Quality, Low Emitting Materials in one of two categories.

- **IEQ Credit 4.1** Low Emitting Materials, Adhesives and Sealants
- **IEQ Credit 4.2** Low Emitting Materials, Paints and Coatings

Foster products may also contribute to LEED MR Credit 5.1 Regional Materials (20% Manufactured Regionally) if the project site is within 500 miles of the Foster manufacturing facility located in Houston, Texas.

Description	Code No.	Category	LEED Credit	VOC (g/L)*
Antimicrobial and Mold Resistant Coatings				
Duct Liner Adhesive Coating	40-10	Coating	4.2	39
ECLIPSE™ Coating	40-11	Coating	4.2	39
Block Filler	40-16	Coating	4.2	15
Foster 40-20™ Fungicidal Coating	40-20	Coating	4.2	36
Masonry Sealer	40-22	Coating	4.2	18
Duct Liner Insulation Sealer	40-23	Coating	4.2	23
Full Defense™ Fungicidal Coating	40-25	Coating	4.2	40
Fungicidal Protective Coating	40-30	Coating	4.2	39
Interior Defense™ Mold Resistant Coating	40-50	Coating	4.2	39
Sheer Defense™ Mold Resistant Coating	40-51	Non-Flat Coating	4.2	<100
Clear Defense™ Exterior Mold Resistant Coating	40-55	Non-Flat Coating	4.2	116
Drip Pan Coating	40-60	Coating	4.2	10
Proactive Defense™ Mold Resistant Sealer	42-42	Coating	4.2	<50
Asbestos Abatement				
PROTEKTOR® Sealant Blue	32-21	Coating	4.2	23
PROTEKTOR® Sealant Clear	32-22	Coating	4.2	18
Bridging Encapsulant	32-32	Coating	4.2	20
SPRAY POLY® Strippable Coating	32-56	Coating	4.2	11
Removal Encapsulant, Clear	32-60	Coating	4.2	10
Removal Encapsulant, Blue	32-61	Coating	4.2	10
Bridging Mastic White	32-80	Coating	4.2	41
Chil-Bridge™ Bridging Encasement/Encapsulant	CP-211-3	Coating	4.2	39
Chil-Lock™ Removal Agent	CP-240	Coating	4.2	0

* Less water and exempt solvents.

The information provided herein has been prepared in good faith on the basis of information available at the time of publication. Because of variations that take place during production in normal working and environmental conditions, Specialty Construction Brands, Inc. cannot be responsible for the consequence of variations in such conditions or for unforeseen conditions.

The trademarks listed on this certification sheet, unless otherwise noted, are owned by Specialty Construction Brands, Inc.

Printed in U.S.A.
©2009 Specialty Construction Brands, Inc.
Form # GD F LEEDR0209

The Foster® products, shown in the table below, comply with U.S. Green Building Council's LEED® requirements for Indoor Environmental Quality, Low Emitting Materials in one of two categories.

- **IEQ Credit 4.1** Low Emitting Materials, Adhesives and Sealants
- **IEQ Credit 4.2** Low Emitting Materials, Paints and Coatings

Foster products may also contribute to LEED MR Credit 5.1 Regional Materials (20% Manufactured Regionally) if the project site is within 500 miles of the Foster manufacturing facility located in Houston, Texas.

Description	Code No.	Category	LEED Credit	VOC (g/L)*
Insulation Products				
Fire Resistive Anti-Abrasion Bore Coating	30-16	Coating	4.2	15
SEALFAS® Coating	30-36	Coating	4.2	15
FOAMSEAL® Sealant	30-45	Sealant (other)	4.1	31
VAPOR-SAFE® Coating	30-80	Coating	4.2	33
VAPOR-SAFE® Mastic	30-90	Coating	4.2	36
SEALFAS G-P-M® Mastic	35-00	Coating	4.2	37
WEATHERITE™ Mastic	36-10	Coating	4.2	31
SEALFAS G-P-M® Mastic	45-00	Coating	4.2	36
AQUA-FAS® Mastic	46-00	Coating	4.2	39
WEATHERITE™ Mastic	46-10	Coating	4.2	33
WEATHERITE™ Mastic Bright	46-50	Coating	4.2	40
WEATHERITE™ Coating Bright	56-10	Coating	4.2	50
Fibrous Adhesive	81-27	Adhesive	4.1	0
Cellular Glass and Urethane Adhesive/Sealant (Two-Part)	81-84	Adhesive	4.1	17
100% Solids Cryogenic Adhesive (Three-Part)	82-77	Adhesive	4.1	0
Facing Laminating Adhesive	85-53	Adhesive	4.1	27
SPARK-FAS® WB Adhesive	85-70	Adhesive	4.1	73
H.I. MASTIC® Emulsion	90-07	Coating	4.2	21
ELASTOLAR® Sealant	95-44	Sealant (other)	4.1	384
FLEXTRA® Sealant	95-50	Sealant (other)	4.1	380
HVAC and Sheet Metal Adhesive, Sealants and Coatings				
VAPOR-FAS™ Vapor Seal & Duct Closure	30-65	Coating	4.2	38
SAFETEE™ Fibrated Duct Sealant	32-17	Sealant	4.1	45
DUCT-FAS™ Non-Fibrated Duct Sealant	32-19	Sealant	4.1	24
LAGFAS® Lagging Adhesive & Coating	81-42W	Adhesive	4.1	10
LINE-FAS® Coil Line Adhesive	85-00	Adhesive	4.1	5
FOS-STIK™ Aerosol Adhesive - Web Spray	85-45	Aerosol Adhesive	4.1	<55%
Pressure Sensitive Adhesive	85-50	Adhesive	4.1	1
QUICK-TACK™ Fast Tack - WB Adhesive	85-60	Adhesive	4.1	4
JAC-TAC® WB Duct Liner Adhesive	85-62	Adhesive	4.1	6
STIC-FAST™ WB Duct Liner Adhesive	85-65	Adhesive	4.1	2
VAPOR-SAFE® Duct Closure Mastic	95-90	Coating	4.2	26
VAPOR-SAFE® Duct Closure Mastic	95-96	Coating	4.2	27

The information provided herein has been prepared in good faith on the basis of information available at the time of publication. Because of variations that take place during production in normal working and environmental conditions, Specialty Construction Brands, Inc. cannot be responsible for the consequence of variations in such conditions or for unforeseen conditions. The trademarks listed on this certification sheet, unless otherwise noted, are owned by Specialty Construction Brands, Inc.

Printed in U.S.A. ©2009 Specialty Construction Brands, Inc.
Form # GD F LEED R0209

* Less water and exempt solvents.

Specialty Construction Brands, Inc.
1105 South Frontenac Street
Aurora, IL 60504
Phone: 800.231.9541 Fax: 800.942.6856
www.fosterproducts.com